



Lead Sampling Procedures

A lead sample must be taken from a faucet that has not been run for at least 6 hours. It is recommended to take the sample from the kitchen or bathroom sink faucet. **DO NOT** intentionally flush the water line before the start of the 6-hour period.

Lead samples are generally taken after 2 p.m. on the day of sampling. You must contact the office for a time between 8-9 a.m. on the day the sample is scheduled for a time.